

# Emission Test Certificate

Wednesday, 11<sup>th</sup> May 2016

Supplier: Terra Mater Hardwood Floors Pty Ltd (43 Nicholas Drive, Dandenong South, VIC 3175)

Sample Description: Terra Mater – Lakewood

Date Tested: April 2016 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<b>Green Building Council of Australia</b>  <b>Green Star Office Design v3 IEQ-13</b>	<b>Terra Mater – Lakewood</b>
Total Volatile Organic Compound Emission Rate limit $<0.5 \text{ mg/m}^2/\text{hr}$	Total Volatile Organic Compound Emission Rate: $0.016 \text{ mg/m}^2/\text{hr}$
4-phenylcyclohexene Emission Rate limit $<0.05$ $\text{mg/m}^2/\text{hr}$	4-phenylcyclohexene Emission Rate: $<0.004 \text{ mg/m}^2/\text{hr}$
Formaldehyde Emission Rate limit $<0.1 \text{ mg/m}^2/\text{hr}$	Formaldehyde Emission Rate: $0.093 \text{ mg/m}^2/\text{hr}$



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Nick Joy  
BSc(Hons)  
Consultant



Tuan Duong  
B Eng. (Chem.)  
Consultant

**CV160428**