

Fire & Smoke Test Certificate

Monday December 05th, 2016

Supplier: Highland Oak (43 Nicholas Drive, Dandenong South, VIC 3175)

Sample Description: LamSeries FM-1409

Date Tested: November 2016

Test Method: ISO 9239-1:2010 Part 1: Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a Radiant Heat Source.

Test Data:

ISO 9239-1:2010 Part 1	LamSeries FM-1409
Critical Heat Flux/Critical Radiant Flux*	5.2 kW/m ²
Smoke Value*	5 % .min
Blistering	Yes
Glowing	Yes
Smoldering	Yes

*Three test average value



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant



Tuan Duong
B. Eng. (Chemical)
Consultant

CV161129a