

Dry Slip Test Certificate

Monday December 05th, 2016

Supplier: Highland Oak (43 Nicholas Drive, Dandenong South, VIC 3175)

Sample Description: LamSeries FM-1409

Date Tested: November 2016 (Tested through FORAY Laboratories – NATA Accreditation 1231)

Test Method: AS/NZS 4586-2004 Appendix B “Slip resistance classification of new pedestrian surface materials – Dry Floor Friction Test Method” using Slider 96

Test Data:

Sample Identification	Dry floor friction result ¹	Classification ² (Standards Australia Handbook 197)
LamSeries FM-1409	0.45	D1

¹ Six test average value

² The classification indicates that the contribution of the floor surfaces to the risk of slipping when dry is moderate to very low



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant



Tuan Duong
B.Eng. (Chemical)
Consultant

CV161129a