

# Fire & Smoke Test Certificate

Monday December 05<sup>th</sup>, 2016

Supplier: Highland Oak (43 Nicholas Drive, Dandenong South, VIC 3175)

Sample Description: LamSeries FM-1409

Date Tested: November 2016

Test Method: AS/ISO 9239-1:2003 Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a Radiant Heat Source.

Test Data:

<b>AS/ISO 9239-1:2003</b>	<b>LamSeries FM-1409</b>
<b>Critical Heat Flux/Critical Radiant Flux*</b>	5.2 kW/m <sup>2</sup>
<b>Smoke Value*</b>	5 % .min
<b>Blistering</b>	Yes
<b>Glowing</b>	Yes
<b>Smoldering</b>	Yes

\*Three test average value



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Nick Joy  
BSc(Hons)  
Consultant



Tuan Duong  
B. Eng. (Chemical)  
Consultant

**CV161129a**