

# Emission Test Certificate

Wednesday, 11<sup>th</sup> October 2017

Supplier: Terra Mater Hardwood Floors Pty Ltd (23-27 Rodeo Drive, Dandenong, VIC 3175)

Sample Description: 5mm DURAPLANK Vinyl Plank

Date Tested: September 2017 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (24 hrs):

<p align="center"><b>Green Building Council of Australia</b> <b>Green Star Office Design v3 IEQ-13</b></p>	<p align="center"><b>5mm DURAPLANK Vinyl Plank</b></p>
<p align="center">Total Volatile Organic Compound Emission Rate limit &lt;0.5 mg/m<sup>2</sup>/hr</p>	<p align="center">Total Volatile Organic Compound Emission Rate: 0.173 mg/m<sup>2</sup>/hr</p>
<p align="center">Formaldehyde Emission Rate limit &lt;0.1 mg/m<sup>2</sup>/hr</p>	<p align="center">Formaldehyde Emission Rate: 0.046 mg/m<sup>2</sup>/hr</p>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Nick Joy  
BSc(Hons)  
Consultant



Tuan Duong  
B Eng. (Chem.)  
Consultant

CV170911